



Telephone 0484-2623576
email: qcdaaluva@gmail.com



KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LAB, ALUVA - 683101

WATER TEST REPORT

ULR NO: TC121192500002640F

Report No: KWA/QCDL-ALY/S/2233/6/25

Report Issue Date: 04.07.2025

Customer Name & Address	Date of Receipt of Payment	20.06.25
St Anne's Public School Koovappady Koovappady P O	Date of Sample received	24.06.25
	Sample given by	MO I/C, FIIC Kodanad
	Sample Code	ALY/S/2233/6/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
Test performing dates : From : 02.07.25 to 04.07.25		

SLN	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part 10)-2023	1.0	BDL(DL=0.1)
2	pH at 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	6.62
3	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21)-2009(Reaffirmed 2023)	200	26
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	9.80
5	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	BDL(DL=0.1)
6	Nitrate (as NO ₃)	mg/L	APHA 24rd Edition-4500-NO ₃ Method B(UV Spectrophotometric Screening Method)	45	9.3
7	Electrical conductivity at 25°C	micromhos/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)(Reaffirmed 2023)	-	70.00

Remarks - DL : Detectable Limit

BDL : Below Detectable Limit

NB -1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Analyzed By Technical Manager

Reviewed By Deputy Quality Manager

Authorized By Quality Manager

End of Report

KWA/QCDL/ALY/01-2020	Issue Date : 04.10.2020	QUALITY CONTROL DISTRICT LAB
Rev No: 03	Rev. Date : 02/06/2025	Page 1 of 1
ENNAKULAM, ALUVA - 683101		





Telephone:0484-2623576
email:-qcdlaluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT

Report No: ALY/B/8164

Report Issue Date: 14.07.2025

Customer Name & Address		Date of Receipt of Payment	07.07.25	
St. Annes Public School Koovappady Perumbavoor		Date of Sample received	08.07.25	
		Sample given by	MO I/C, FHC Kodanad	
		Sample Code	ALY/B/8164	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Open Well	
		Sample Quantity	250ml	
		Test performing dates :	From :08.07.25 to 09.07.25	
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Asd (DQM)
Analyzed By

For *Asd (DQM)*
Authorized By Quality Manager

End of Report

KWA/QCDL/ALY/01-2020		Issue Date : 04.10.2020	
Rev No: 03	Rev,Date : 02/06/2025	Page 3 of 3	QUALITY MANAGER KWA, QUALITY CONTROL DISTRICT LAB ERNAKULAM, ALUVA - 683 101

